

**DEPARTMENT OF TRANSPORTATION**

ESC/OE MS #43  
1727 30TH Street, 2ND Floor  
Sacramento, CA 95816



May 23, 2000

11-SD-805-36.5/43.0  
11-224404

Addendum No. 1

Dear Contractor:

This addendum is being issued to the contract for Highway Erosion Control on State Highway in SAN DIEGO COUNTY IN SAN DIEGO FROM CLAIRMONT MESA BOULEVARD OVERCROSSING TO 0.3 km NORTH OF LA JOLLA VILLAGE DRIVE OVERCROSSING.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on June 1, 2000.

This addendum is being issued to revise the Project Plans, the Notice to Contractors and Special Provisions, and the Proposal and Contract.

On Project Plan Sheet 3 through Project Plan Sheet 17, the "SOIL SEALANT" work shall not be performed.

On Project Plan Sheet 19, the quantity tables for "SOIL SEALANT" and "SOIL STABILIZATION" are to be deleted.

In the Special Provisions, Section 10-1.17, "SOIL SEALANT," is deleted.

In the Special Provisions, Section 10-1.18, "SOIL STABILIZATION," is replaced as attached.

In the Proposal and Contract, the Engineer's Estimate Item 10 is revised, and Item 11 is deleted as attached.

To Proposal and Contract book holders:

REPLACE PAGE 3 OF THE ENGINEER'S ESTIMATE IN THE PROPOSAL WITH THE ATTACHED REVISED PAGE 3 OF THE ENGINEER'S ESTIMATE. THE REVISED ENGINEER'S ESTIMATE IS TO BE USED IN THE BID.

INDICATE RECEIPT OF THIS ADDENDUM BY FILLING IN THE NUMBER OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE SIGNATURE PAGE OF THE PROPOSAL.

SUBMIT BIDS IN THE PROPOSAL AND CONTRACT BOOK YOU NOW POSSESS. HOLDERS WHO HAVE ALREADY MAILED THEIR BOOK WILL BE CONTACTED TO ARRANGE FOR THE RETURN OF THEIR BOOK.

INFORM SUBCONTRACTORS AND SUPPLIERS AS NECESSARY.

Addendum No. 1  
Page 2  
May 23, 2000

11-SD-805-36.5/43.0  
11-224404

This office is sending this addendum by confirmed facsimile to all book holders to ensure that each receives it.

If you are not a Proposal and Contract book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

NICK YAMBAO, Chief  
Office of Plans, Specifications & Estimates  
Division of Office Engineer

Attachments

#### **10-1.17°°SOIL STABILIZATION**

Soil stabilization shall consist of preparing soil, applying and incorporating stabilizing emulsion, grading and compacting the mixture to the dimensions shown on the plans and as specified in these special provisions.

Stabilizing emulsion shall conform to the provisions in Section 20-2.11, "Stabilizing Emulsion," of the Standard Specifications. Stabilizing emulsion shall be applied in a liquid form at the rate of 1.66 kilograms of solids per cubic meter of soil to be stabilized. The ratio of total water to total stabilizing emulsion in the mixture shall be as recommended by the manufacturer. The stabilization emulsion mixture shall be thoroughly mixed into the soil to a depth of 100 mm to uniformly coat all soil particles.

Soil shall be scarified to a depth of 150 mm. Soil clods shall not be larger than 15 millimeters in any direction.

After the stabilizing emulsion mixture has been thoroughly mixed with the soil, the area shall be graded to a smooth slope. The soil shall then be compacted in conformance with the provisions in Section 19-6.02, "Compacting," of the Standard Specifications. Treated soil that contains excessive moisture shall not be compacted until the material is sufficiently dry to obtain the required compaction.

A relative compaction of not less than 90 percent shall be obtained to the full depth of the soil being treated. The finished surface shall be smooth, graded to the original slope.

Soil stabilization will be measured and paid in the same manner as stabilization emulsion as provided for in Sections 20-3.06, "Measurement," and 20-3.07, "Payment," of the Standard Specifications.

The contract price paid per kilogram for soil stabilization shall include full compensation for furnishing all labor, materials, tools, equipment, and incidentals, and for doing all the work involved in soil stabilization complete in place, including furnishing and incorporating stabilizing emulsion, grading and compacting, as shown on the plans, as specified in the Standard Specifications and these special provisions, and as directed by the Engineer.

**ENGINEER'S ESTIMATE  
11-224404**

Item	Item Code	Item	Unit of Measure	Estimated Quantity	Unit Price	Item Total
1	074019	PREPARE STORM WATER POLLUTION PREVENTION PLAN	LS	LUMP SUM	LUMP SUM	
2	074020	WATER POLLUTION CONTROL	LS	LUMP SUM	LUMP SUM	
3	074028	TEMPORARY FIBER ROLL	M	1600		
4	074029	TEMPORARY SILT FENCE	M	2300		
5	017971	TEMPORARY CONSTRUCTION ENTRANCE	EA	3		
6	017972	TEMPORARY FENCE (TYPE ESA)	M	2000		
7	120090	CONSTRUCTION AREA SIGNS	LS	LUMP SUM	LUMP SUM	
8	017973	PREPARE SLOPE	M2	44°800		
9	190101	ROADWAY EXCAVATION	M3	1780		
10	017974	SOIL STABILIZATION	KG	490		
11	<del>017975</del>	<del>SOIL SEALANT</del>	<del>M2</del>	<del>12 400</del>		
12	200002	ROADSIDE CLEARING	LS	LUMP SUM	LUMP SUM	
13	017976	SOIL AMENDMENT (NITORLIZED SHAVINGS)	M3	212		
14	202011	MULCH	M3	1500		
15	202032	COMMERCIAL FERTILIZER (TABLET)	EA	90°700		
16	017977	HYDROSEED	M2	6700		
17	203561	JUTE MESH	M2	44°800		
18	204006	PLANT (GROUP F)	EA	15°600		
19	204008	PLANT (GROUP H)	EA	12°900		
20	204035	PLANT (GROUP A)	EA	29°900		